



SHEET KEYNOTES

1. ROUTE PIPES BELOW GRADE AND UP THROUGH SLAB. TRANSITION FROM HDPE TO DUCTILE IRON OUTSIDE OF BUILDING FOOTPRINT. SEE CIVIL FOR LOCATION.
2. ROUTE PIPES THROUGH EXTERIOR WALL. SEAL WALL PENETRATION WEATHER-TIGHT AND FINISHED APPEARANCE.
3. ROUTE PIPE ABOVE GRADE TO WATER STORAGE TANK. SEE CIVIL FOR TANK PIPE CONNECTION DETAILS. EXTERIOR PIPE SHALL BE INSULATED AND HEAT TRACED WITH WEATHER-TIGHT ALUMINUM JACKETING
4. SV-01 SHALL HAVE A SETPOINT PRESSURE OF 75 PSIG.

DESIGN	ALN
DRAWN	TRS
CHECKED	LAR
DATE	04-16-2025
PROJECT No.	
10297.24002	
SHEET NUMBER	

YAKUTAT, ALASKA

SHEET TITLE :
PUMP HOUSE FLOOR PLAN -
PROCESS

DESIGN	AL
DRAWN	TR
CHECKED	LA
DATE	04-16-202
PROJECT No. 10297.24002	
SHEET NUMBER	

D-112

MECHANICAL FLOOR PLAN

3	9/24/25	ADDENDUM #3
No.	Date	Item
REVISIONS		